



CITY OF
**West
Linn**

**2013 Library Parking
Expansion (PW-13-08)**

**Prospective Bidder's Conference
Meeting Minutes, July 1, 2013**

Public Works Department
22500 Salamo Road
West Linn, OR 97068
Telephone: (503) 722-5500
Fax: (503) 656-41-6

Attendance: Erich Lais, Khoi Le, Jeanie Braun

1. Clarification #1: On page C5.1, construction note 2, "replace existing parking lot light bulb (6) with LED light bulb." The existing parking lot lights have already been retrofitted with LED bulbs
2. Clarification #2: On page C2.1, construction note 6, "group of trees to be removed." City staff will be performing this work.
3. Clarification #3: There is no landscape irrigation included in this project.
4. Clarification #4: For planting, use 18-inch minimum native top soil where applicable, if additional is needed use a 3-way blend (will be an extra pay item); use 3 to 4-inches of mulch (garden compost) on top of that.
5. Clarification #5: See rain garden details on page C4.3 for dimensions.