

**ADDENDUM NO. 2
TO THE BID DOCUMENTS FOR
Water Main Replacement Project 2013
Project #PW-1219/1303/1304/1305 - FOR THE CITY OF WEST LINN**

This addendum is hereby made a part of the contract documents to the same extent as though it were originally included therein.

Engineering Department
City of West Linn, OR
22500 Salamo Road #800
West Linn, OR 97068
503-722-5519, FAX 503-656-4106

Issued: February 1, 2013
Issued by: B Piatski, PE
Project Manager

ITEM NO. 1 Public Works Standards, City of West Linn Public Works Standard Construction Specifications, Page 3, 402.10 B :

The auxiliary valve shall be Mueller resilient seat No. A-2370-16 only and be furnished complete with cast iron valve box, complete with cover, galvanized bolts and gaskets,

Change to:

The auxiliary valve shall be Mueller resilient wedge gate valve No. A-2360-16, or approved equal, and be furnished complete with cast iron valve box, complete with cover, galvanized bolts and gaskets.

ITEM NO. 2– Public Works Standards, Standard Drawings , WL-401 - Standard Fire Hydrant Assembly, Note #10:

Hydrant valve shall be Mueller Resilient Wedge gate valve # A- 2360-16 only.

Change to :

The auxiliary valve shall be Mueller resilient wedge gate valve No. A-2360-16, or approved equal, and be furnished complete with galvanized bolts and gaskets.

ACKNOWLEDGEMENT OF RECEIPT OF THE ADDENDA (acknowledge with Bid):

_____ Date: _____
Signature of Bidder

Title

Company Name and Address: _____

_____.