

**ADDENDUM NO. 3
TO THE BID DOCUMENTS FOR
STREET MAINTENANCE PROGRAM 2009
PROJECT PW0909 - FOR THE CITY OF WEST LINN**

This addendum is hereby made a part of the contract documents to the same extent as though it were originally included therein.

Engineering Department
City of West Linn, OR
22500 Salamo Road #800
West Linn, OR 97068
503-722-5519, FAX 503-656-4106

Issued: March 23, 2009
Issued by: Boris Piatski
Civil Engineer

**ITEM NO. 1 – BID ITEMS DESCRIPTION, ITEM NO.11 CEMENT TREATED
BASE; DRAWINGS, PAGES 51- 62**

Bid Item # 11, Cement Treated Base – **Change** line #8 after AASHTO T-26:
The cement content shall be 6% of the dry density weight 110 lb per C.F.
Drawings, with detail for Cement Treated Base: **Change** note showing **#5 per
SQ.F to 6% of Dry Density Weight.**

ACKNOWLEDGEMENT OF RECEIPT OF THE ADDENDA (acknowledge with Bid):

_____ Date: _____
Signature of Bidder

Title

Company Name and
Address: _____