

**ADDENDUM NO. 4
TO THE BID DOCUMENTS FOR
Mapleton Sewer Rehabilitation Project
PROJECT PW1004 - FOR THE CITY OF WEST LINN**

This addendum is hereby made a part of the contract documents to the same extent as though it were originally included therein.

Engineering Department
City of West Linn, OR
22500 Salamo Road #800
West Linn, OR 97068
503-722-5519, FAX 503-656-4106

Issued: April 12, 2010
Issued by: Boris Piatski, PE
Civil Engineer

1. Special Specifications – 35. Sewage Diversion Requirements Pg 37 (A) insert after the 4th sentence

.....during all elements of construction. **The flow through the pipe shall be diverted and pipe shall be flushed prior to insertion of the CIPP.** The plan.....

2. Change where applicable – Bid Documents, Advertisement, checklist, etc. –

BIDS DUE: 2:00 PM, Wednesday, **April 29, 2010**; West Linn City Hall, 22500 Salamo Road, Mail Stop #800, West Linn, Oregon 97068.

BID OPENING: 2:00 PM, Wednesday, **April 29, 2010**; West Linn City Hall, 22500 Salamo Road, West Linn, Oregon 97068.

FIRST TIER DISCLOSURE STATEMENTS DUE: 4:00 PM, Wednesday, **April 29, 2010**; West Linn City Hall, 22500 Salamo Road, West Linn, Oregon 97068.

ACKNOWLEDGEMENT OF RECEIPT OF THE ADDENDA (acknowledge with Bid):

_____ Date: _____
Signature of Bidder

Title

Company Name and Address: _____

