



SANITARY SEWER SPECIFICATIONS

1. Materials and workmanship shall comply with City of West Linn Standard Specifications.
2. Contractor shall verify all utility locations 48 hours prior to commencement of excavation.
3. Contractor shall obtain all permits and licenses prior to commencement of work.
4. Class "B" bedding and select granular backfill required in all pavement areas. Class "C" bedding and approved native backfill in other areas.
5. Pipe : Concrete with Rubber Ring Gaskets ASTM C-14 Cl. 2
6. Manholes: 48" I.D. Precast ASTM C-478

— — — — Telephone
— · — · — Electric

	4		
	3		
11-14-80	2	RDK	
9-5-80	1	JHC	
DATE	NO.	BY	
REVISIONS			

MEADOWVIEW ESTATES
WEST LINN, OREGON

SANITARY SEWER EXTENSIONS PLAN & PROFILE

Scale: As Noted

JOHN W. CUNNINGHAM & ASSOC.
CONSULTING ENGINEERS — MILWAUKIE, OREGON

DESIGN HSB RDK	DATE DEC. 10, 1979	F	915-B-1
DRAWN JHC	NO. 1 OF 2	JOB	5711

Meadowview Estates

MEADOWVIEW ESTATES '79



WATER SYSTEM SPECIFICATIONS

1. Materials and workmanship shall comply with City of West Linn Standard Specifications.
2. Contractor shall verify all utility locations 48 hours prior to commencement of excavation.
3. Contractor shall obtain all permits and licenses prior to commencement of work.
4. Class "B" bedding and select granular backfill required in all pavement areas. Class "C" bedding and approved native backfill in other areas.
5. Concrete thrust blocks shall have a minimum of 3 sq. ft. of bearing against undisturbed earth.
6. Minimum Cover = 3'-0"
7. Service tubing shall be type "K" soft copper or approved polybutylene with compression fittings.
8. Service connections shall include angle stop and meter box. Fill box with sawdust following installation of meter.
9. Water Dept. approval of Fire Hydrant required before ordering.



BLOWOFF ASSEMBLY
N.T.S.



FIRE HYDRANT ASSEMBLY
N.T.S.

DATE	NO.	BY
	4	
	3	
	2	
9-5-80	1	JHC
REVISIONS		

REGISTERED PROFESSIONAL ENGINEER
2102
OREGON
U.S.A.

As Built
9-5-80

MEADOWVIEW ESTATES
WEST LINN, OREGON

WATER SYSTEM EXTENSIONS

Scale: 1" = 50'

JOHN W. CUNNINGHAM & ASSOCIATES
CONSULTING ENGINEERS — MILWAUKIE, OREGON

DESIGN	NSB RDK	DATE DEC. 10, 1979	F 915-B-2
DRAWN	JHC	NO. 2 OF 2	E 5712



WATER SYSTEM SPECIFICATIONS

1. Materials and workmanship shall comply with City of West Linn Standard Specifications.
2. Contractor shall verify all utility locations 48 hours prior to commencement of excavation.
3. Contractor shall obtain all permits and licenses prior to commencement of work.
4. Class "B" bedding and select granular backfill required in all pavement areas. Class "C" bedding and approved native backfill in other areas.
5. Concrete thrust blocks shall have a minimum of 3 sq. ft. of bearing against undisturbed earth.
6. Minimum Cover = 3'-0"
7. Service tubing shall be type "K" soft copper or approved polybutylene with compression fittings.
8. Service connections shall include angle stop and meter box. Fill box with sawdust following installation of meter.
9. Water Dept. approval of Fire Hydrant required before ordering.

OOE RECORDS
12-20-79 JWD



BLOWOFF ASSEMBLY
N.T.S.



FIRE HYDRANT ASSEMBLY
N.T.S.

REGISTERED PROFESSIONAL ENGINEER 2103 OREGON JULY 9, 1971 H. S. LARSEN

MEADOWVIEW ESTATES
WEST LINN, OREGON

WATER SYSTEM EXTENSIONS

Scale : 1" = 50'

JOHN W. CUNNINGHAM & ASSOCIATES
CONSULTING ENGINEERS MILWAUKIE, OREGON

DATE	NO.	BY
REVISIONS		
	4	
	3	
	2	
	1	

DESIGN	HSB RDK	DATE DEC. 10, 1979	F 915-B-2
DRAWN	JHC	NO. 2 OF 2	E 5712

MEADOWVIEW EST. - K





SANITARY SEWER SPECIFICATIONS

1. Materials and workmanship shall comply with City of West Linn Standard Specifications.
2. Contractor shall verify all utility locations 48 hours prior to commencement of excavation.
3. Contractor shall obtain all permits and licenses prior to commencement of work.
4. Class "B" bedding and select granular backfill required in all pavement areas. Class "C" bedding and approved native backfill in other areas.
5. Pipe: Concrete with Rubber Ring Gaskets ASTM C-14 Cl. 2
6. Manholes: 48" I.D. Precast ASTM C-478

Our Records
12-20-79 JWC

DATE	NO.	BY
	4	
	3	
	2	
	1	
REVISIONS		

MEADOWVIEW ESTATES
WEST LINN, OREGON

SANITARY SEWER EXTENSIONS PLAN & PROFILE

Scale: As Noted

JOHN W. CUNNINGHAM & ASSOC.
CONSULTING ENGINEERS — MILWAUKIE, OREGON

DESIGN HSB RDK	DATE DEC. 10, 1979	F	915-B-1
DRAWN JWC	NO. 1 OF 2	E	5711

PLAN — SURVEYED — PLOTTED — NOTE BOOK — GRADES CHECKED — AS-BUILT NOTATIONS CHECKED — No. — DATE — BY

PROFILE — SURVEYED — PLOTTED — NOTE BOOK — AS-BUILT NOTATIONS CHECKED — No. — DATE — BY


JOHNSON
ROAD
30'
30'
HOUSE
5
4
3
6
7
2
8
AT LOWEST POINT INSTALL CATCH BASIN GRATE ELEV. 121.50 F.L. ELEV. 119.50 T.Curb 122.00
AT LOWEST POINT INSTALL CATCH BASIN GRATE ELEV. 120.00 F.L. 116.00
T.C. 122.50
T.Curb 122.4
T.Curb 122.4
TAPER DRIVEWAY TO EDGE OF ROAD PAVEMENT
17' Curb RADIUS
12" Culvert To DROW ALONG TOE OF Rock Fill
RESHAPE CHANNEL AS NECESSARY TO DRAIN PROPERLY
TAPER TO MEET EXIST. ROADWAY
INSTALL 70-60 COATED C.M.P.
E.E. 116.1
EXISTING 36" CONC. CULVERT IN HEADWALLS (TO BE REMOVED & REPLACED BY 60" COATED C.M.P. ON MIN. 2% GRADE)
APPROX. LOCATION OF PROPOSED SANITARY SEWER.
2 1/2" diam CEDAR TREES
Curb Radius 17'
Curb 7
7'
Ex. 36" Culvert
Ex. 36" Culvert
Ex. 36" Culvert

PLAN
SURVEYED
PLOTTED
NOTE BOOK CLASSES CHECKED
No. R. R.'s NOTED
ST. OF WAY CHECKED
STRUCTURE NOTATIONS CHECKED
BY
DATE

PROFILE
SURVEYED
PLOTTED
NOTE BOOK CLASSES CHECKED
No. R. R.'s NOTED
STRUCTURE NOTATIONS CHECKED
BY
DATE

JOHNSON ROAD

30'

EDGE OF EXIST. PAVEMENT

INSTAL CATCH BASIN GRATE ELEV. 131.50 F.L. ELEV. 113.50

INSTAL CATCH BASIN GRATE ELEV. 131.80 F.L. 120.00

Build C.B. at low point of curve

TAPER TO MEET EXIST. ROADWAY

TAPER HEAD 3' 12' Curb RADIUS

INSTALL 50'± OF 36" CMPC CULVERT

RESHAPE CHANNEL AS NECESSARY TO DRAIN PROPERLY

EXISTING 36" CMPC CULVERT IN HEADWALLS

Provide for 160 cfs

Provide: Headwall Pipe(s) size Grade

Detail at right

MEADOWVIEW COURT

APPROX. LOCATION OF PROPOSED SANITARY SEWER

House

Cedar Fence

2" Deciduous CEDAR TREES

Curb Radius Typ.

Show typical:
Street Section
Curb detail
Catch Basin

Identify degree of compaction on street subgrade & paving material

SCALE: VERT. 1"=5'
HORIZ. 1"=50'

PROFILE OF MEADOWVIEW COURT

Ground Profile Rt. Curb Line

Ground Profile Left Curb Line

℄ Ground Profile

Rt. Curb line Ground Profile

Lt. Curb line Ground Profile (Approx Grade Existing Roadway)

GRADE BREAK STA. 4+48.05 ELEV. 130.05

NOTE: GRADE CARRIED ON FACE OF CURB FROM STA 3+90.94 TO STA 5+64.75

-0.73% GR.

-1.50% GR.

P.C. (Lt.) 4+64.21
P.R.C. (Lt.) 4+74.73

P.C. (Rt.) 4+48.05
P.R.C. (Rt.) 4+45.11

℄ P.C.C. 3+90.94

℄ P.T. 3+45.94

℄ P.C. 3+52.94

P.T.C.C. 2+25 Elev. 147.88

P.C.C.C. 2+25 Elev. 147.5

P.R.C. 2+00 Elev. 145.16

P.T.C. 0+05 Elev. 121.80

℄ Johnson Rd. Grade Elev. 122.30

GRATE ELEV. Rt ℄ Lt. 131.50
INSTALL CATCH BASINS Lt & Rt. SIDE

F.L. ELEV. (Lt.) 120.00

F.L. ELEV. (Rt.) 120.50

50' 36" CMPC

F.L. EXIST. 36" Culvert 116.44

Approx. outlet ELEV. 117.0

F.L. (out) Exist. 36" Cul. 115.04

155 150 145 140 135 130 125 120 115

4+00 3+00 2+00 1+00 0+00

R=100.0'

PRELIMINARY
SUBJECT TO CHANGE
12-21-79

DICK LOVE
657-5747
656-4415
220 Abernethy Lane
Gladstone 97027

CONSTRUCTION PLAN & PROFILE
FOR
STREETS, CURBS AND STORM DRAINAGE
ON THE PLAT OF
MEADOWVIEW ESTATES
CITY OF WEST LINN, ORE.

REVISIONS

DRAWN BY:
DATE-12/21/79
JOB NO. 78-513

CHECKED & APPROVED BY:
CUNNINGHAM ASSOCIATES, INC.
PROJECT ENGINEERS PHONE: 653-0753
9401 S.E. McLOUGHLIN BLVD - MILWAUKIE ORE.

HIGHWAY FEDERAL AID SHEET
PLATE 1-SINGLE PLAN AND PROFILE-FULL LINE
TELEDYNE
PRINTED IN U.S.A.

PLAN — SURVEYED / PLOTTED / NOTE BOOK / No. — ALIGNMENT CHECKED / ST. OF WAY CHECKED / GRADES CHECKED / STRUCTURE NOTATIONS CHECKED — DATE / BY


JOHNSON
ROAD
30'
HOUSE
MEADOWVIEW COURT
5
6
4
3
7
2
8
1
AT LOWEST POINT INSTALL CATCH BASIN GRATE ELEV. 121.50' F.L. ELEV. 119.50 4 CURB 122.00
AT LOWEST POINT INSTALL CATCH BASIN GRATE ELEV. 120.00' F.L. 120.00'
T.C. 122.50
T. Curb 122.4
18" Culvert to DRAIN ALONG TOE OF ROCK Fill
TAPER DRIVEWAY TO MEET EDGE OF EXIST. PAVEMENT
17' Curb RADIUS
18" CMP
RESHAPE CHANNEL AS NECESSARY TO DRAIN PROPERLY
EXISTING 24" CONC. CULVERT IN HEADWALLS TO BE REMOVED & REPLACED BY 1 60" COATED C.M.P. ON MIN. 2% GRADE
I.E. 116.0
INSTALL 57'-60" COATED C.M.P.
TAPER TO MEET EXIST. ROADWAY
Curb Radius 17.0'
2" dbh CEDAR TREES
APPROX. LOCATION OF PROPOSED SANITARY SEWER
Ground Profile Rt Curb Line
Ground Profile Lft Curb Line
Lft. Curb Line Ground Profile (Approx Grade Existing Roadway)
Rt Curb Line Ground Profile
& Ground Profile
Ground Profile & Curb Line
Ground Profile & Curb Line
Ground Profile & Curb Line