

CITY OF WEST LINN
WATER CALCULATION FOR METER SIZING



Permit Number:

Date of Calculation:

Project Address:

TYPE OF FIXTURE	# FIXTURES	PRIVATE	TOTAL	PUBLIC	TOTAL
BATHTUBS or BATH/SHOWER COMBO		4	0	4	0
BATHTUB WITH 3/4" VALVE		10	0	10	0
BIDETS		1	0		
CLOTHES WASHERS		4	0	4	0
DENTAL UNIT, CUSPADOR				1	0
DISHWASHER, DOMESTIC		1.5	0	1.5	0
DRINKING FOUNTAINS		1	0	2	0
HOSE BIBBS (first hose bibb)		2.5	0	2.5	0
HOSE BIBB (additional)		1	0	1	0
LAVATORY "Sink"		1	0	1	0
LAWNSPRINKLERS		1	0	1	0
MOBILE HOMES (EACH)		12	0		
SINKS					
BAR SINKS		1	0	2	0
CLINICAL SINK				3	0
CLINICAL FLUSHOMETER VALVE				8	0
KITCHEN SINK		1.5	0	1.5	0
LAUNDRY SINK		1.5	0	1.5	0
SERVICE SINK OR MOP BASIN		1.5	0	3	0
WASHUP EACH SET OF FAUCETS				2	0
SHOWER, PER HEAD		2	0	2	0
URINAL, 1.0 GPF FLUSHOMETER VALVE					
URINAL, GREATER THAN 1.0 GPF FLUSHOMETER					
URINALS, FLUSH TANK		2	0	2	0
WASH FOUNTAIN, CIRCULAR SPRAY				4	0
WATER CLOSET "Toilet", 1.6 GPF GRAVITY		2.5	0	2.5	0
WATER CLOSET "Toilet", 1.6 GPF FLUSHOMETER TANK		2.5	0	2.5	0
WATER CLOSET "Toilet", 1.6 GPF FLUSHOMETER VALVE					0
WATER CLOSET "Toilet", GREATER THAN 1.6GPF GRAVITY		3	0	5.5	0
WATER CLOSET "Toilet", GREATER THAN 1.6GPF FLUSHOMETER					0
		PRIVATE		PUBLIC	
TOTAL NUMBER OF FIXTURE UNITS			0		0
60 PSI. AVAILABLE PRESSURE AT MAIN			60		60
LENGTH OF SERVICE TO MOST REMOTE FIXTURE					
SIZE OF WATER METER			5/8		
SIZE OF BUILDING SUPPLY LINE			1 1/4		
SIZE OF BUILDING SEWER LINE			3		

See OPSC 610.10

See OPSC 610.10

See OPSC 610.10

See OPSC 610.10

Please Fill out Number of fixtures line. Department will do calculations.

