

**ADDENDUM NO. 1
TO THE BID DOCUMENTS FOR
Mapleton Sewer Rehabilitation Project
PROJECT PW1004 - FOR THE CITY OF WEST LINN**

This addendum is hereby made a part of the contract documents to the same extent as though it were originally included therein.

Engineering Department
City of West Linn, OR
22500 Salamo Road #800
West Linn, OR 97068
503-722-5519, FAX 503-656-4106

Issued: April 5, 2010
Issued by: Boris Piatski
Civil Engineer

ITEM NO. 1 – SPECIAL SPECIFICATIONS, PAGE 20,

Item No. 33 Sanitary Sewer Main Cleaning and TV Inspection, Part 2, B.2a regarding High Velocity Cleaning Equipment with Vacuum Pickup of Materials – Under a. - starting with providing up to 200 gallons – please **REPLACE** with:

- a. **providing up to 60 or higher gallons per minute**.....

ACKNOWLEDGEMENT OF RECEIPT OF THE ADDENDA (acknowledge with Bid):

_____ Date: _____
Signature of Bidder

Title

Company Name and Address: _____

_____.