

NOTE:


1. ALL WALL THICKNESS ON THIS PAGE ARE 8" UNLESS OTHERWISE NOTED.

STEEL NOTES:


- A. CODES SPECIFICATIONS: STEEL CONSTRUCTION SHALL CONFORM TO THE SPECIFICATIONS AND STANDARDS AS CONTAINED IN THE CURRENT EDITION OF THE AISC MANUAL OF STEEL CONSTRUCTION.
- B. MATERIAL: STRUCTURAL SHAPES, BARS, PLATES, AND SHEETS INDICATED ON THE DRAWINGS SHALL BE STEEL MEETING ASTM A36 SPECIFICATIONS. BOLTS SHALL CONFORM TO ASTM A307.
- C. WELDING: WELDING SHALL CONFORM TO AWS D1.1 CODE FOR ARC AND GAS WELDING IN BUILDING CONSTRUCTION. ELECTRODE SHALL BE E70XX LOW HYDROGEN GROUP. WELDING SHALL BE CONDUCTED BY WELDERS CERTIFIED BY THE AWS. ALL WELDS SHALL BE MIN 3/16" FILLET UNLESS OTHERWISE NOTED.
- D. HOT DIP GALVANIZING: UNLESS OTHERWISE NOTED, ALL STEEL FABRICATIONS SHALL BE HOT DIP GALVANIZED AFTER FABRICATION.

The selection and use of this Standard Drawing, while designed in accordance with generally accepted engineering principles and practices, is the sole responsibility of the user and should not be used without consulting a Registered Professional Engineer.

NOTE:  
All material and workmanship shall be in accordance with the City of West Linn Standard Construction Specifications.

 **City of West Linn**  
PUBLIC WORKS DEPARTMENT - STANDARD DRAWINGS  
22500 Salamo Road, West Linn OR 97068  
Phone: 503-722-5500  
www.westlinnoregon.gov

Title: STANDARD INLET AND OUTLET HEADWALL STRUCTURE (FOR OUTLETS OF 36" DIA. OR GREATER)

Approved:  City Engineer

Standard Drawing No.  
WL-DET1350

Effective Date:  
10/15/18