

- 1. DROP BOWL SHALL BE MANUFACTURED BY RELINER-DURAN INC. OR APPROVED EQUAL.
- 2. DROP BOWL SHALL BE SIZED ACCORDING TO MANUFACTURER'S RECOMMENDATIONS.
- 3. PIPE AND FITTINGS FOR DROP ASSEMBLY SHALL BE DUCTILE IRON, AWWA C-900 OR PVC ASTM 3034 SDR 35.
- 4. STAINLESS ADJUSTABLE PIPE BRACKETS SHALL BE MANUFACTURED BY RELINER-DURAN INC. OR APPROVED EQUAL.
- 5. NO MORE THAN ONE DROP BOWL WILL BE ALLOWED PER MANHOLE WITHOUT PERMISSION OF CITY.
- 6. WRITTEN APPROVAL FROM CITY IS REQUIRED FOR DROP BOWL INSTALLATION ON PIPELINES WITH A SLOPE OF 5% OR GREATER.

ile: INSIDE

tandard Drawing No

CONNECTION

MANHOLE

DROP

WL-RD350.dwg